



HYPERSCALE FIRE

VISUAL INSPECTION FREQUENCIES

<u>Component</u>	<u>Initial /</u>	<u>Monthly</u>	<u>Quarterly</u>	<u>Semiannually</u>	<u>Annually</u>
<u>1. Control Equipment: Fire Alarm Systems Monitored for Alarm, Supervisory, and Trouble Signals</u>					
Fuses	x				x
Interfaced equipment	x				x
Lamps and LEDs	x				x
Primary power supply	x				x
<u>2. Control Equipment: Fire Alarm Systems Unmonitored for Alarm, Supervisory, and Trouble Signals</u>					
Fuses	x (weekly)				
Interfaced equipment	x (weekly)				
Lamps and LEDs	x (weekly)				
Primary power supply	x (weekly)				
<u>3. Batteries</u>					
Lead-acid	x	x			
Nickel-cadmium	x			x	
Primary (dry cell)	x	x			
Sealed lead-acid	x			x	
<u>4. Transient Suppressors</u>					
	x			x	
<u>5. Fire Alarm Control Unit Trouble Signals</u>					
	x (weekly)			x	
<u>6. Fiber-Optic Cable Connections</u>					
	x				x
<u>7. Emergency Voice / Alarm Communications Equipment</u>					
	x			x	
<u>8. Remote Annunciators</u>					
	x			x	
<u>9. Initiating Devices</u>					
Air sampling	x			x	
Duct detectors	x			x	
Electromechanical releasing devices	x			x	
Fire extinguishing systems	x			x	
Suppression system switches	x			x	
Fire alarm boxes	x			x	
Heat detectors	x			x	
Radiant energy fire detectors	x		x		
Smoke detectors	x			x	
Supervisory signal devices	x		x		
Waterflow devices	x		x		
<u>10. Guard's Tour Equipment</u>					
	x			x	
<u>11. Combination Systems</u>					
Fire extinguisher monitoring device/systems	x			x	



HYPERSCALE FIRE

<u>Component</u>	<u>Initial /</u>	<u>Monthly</u>	<u>Quarterly</u>	<u>Semiannually</u>	<u>Annually</u>
	<u>Reacceptance</u>				
<u>Carbon monoxide detectors / systems</u>	x			x	
<u>12. Interface Equipment</u>	x			x	
<u>13. Alarm Notification Appliances</u> <u>- Supervised</u>	x			x	
<u>14. Exit Marking Audible Notification</u> <u>Appliances</u>	x			x	
<u>15. Supervising Station Fire Alarm Systems - Transmitters</u>					
DACT	x			x	
<u>DART</u>	x			x	
McCulloh	x			x	
<u>RAT</u>	x			x	
<u>16. Special Procedures</u>	x			x	
<u>17. Supervising Station Fire Alarm Systems - Receivers</u>					
DACR	x	x			
DARR	x			x	
McCulloh systems	x			x	
Two-way RF multiplex	x			x	
RASSR	x			x	
RARS	x			x	
Private microwave	x			x	
<u>18. Public Fire Alarm Reporting System Transmission Equipment</u>					
Publicly accessible fire alarm box	x			x	
Auxiliary box	x				x
Master box					
Manual operation	x			x	
Auxiliary operation	x				x